



DISTRICT LEVEL WATER ANALYSIS LABORATORY

Uttar Pradesh Jal Nigam (Gramin)

Address- Office of Executive Engineer, Division Office Village
Bhansariya, Lalpur Barrier, Gola Road Lakhimpur Kheri (UP) 262701

No. 1813 /WS-19/ 97 Date: 23-05-26

ANNEXURE-C

SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

It is certified that an inspection team headed by **Deputy Quality Manager , Mr. RANDHIR** from District Level Water Analysis Laboratory, U.P. Jal Nigam (Gramin) Lakhimpur Kheri inspected the “**S.P.INTERNATIONAL SCHOOL, Mohammadi Road,Dherayan,Mamri,Gola Lakhimpur-Kheri UP 262802**” on 22/05/2026 and on the basis of water test Report (Attached) bearing No. **U3001371S36786136** Dated 23/05/2026 of District Level Water Analysis Laboratory, UP Jal Nigam (Rural) Lakhimpur Kheri certified that the “**S.P.INTERNATIONAL SCHOOL**” has safe drinking water facilities for the student and member of the staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per the norm prescribed by the Central/State/U.T.Govt.

This certificate is valid for the period of one year.

Singnatur with Seal:

Name: Er.Saurabh Kumar Varma

Designation: : Assistant Engineer

District Level Water Analysis Laboratory
UP Jal Nigam (Gramin) Lakhimpur Kheri

कायालय

अधिशाली अभियन्ता

निर्माण खण्ड, उ०प्र० जल निगम
लखीमपुर-खीरी

To,

S.P.INTERNATIONAL SCHOOL

Mohammadi Road,Dherayan,Mamri,Gola

District Lakhimpur (Kheri)

262802

District Level Water Analysis Laboratory, U.P Jal Nigam (Rural), Lakhimpur Khiri

Office of Executive Engineer, Construction division, U.P Jal Nigam, Village-Bhansariya Lalpur Barer, Lakhimpur Khiri, Pin-262701. (Test Address only)

Test report

Sample Id: U3001371536786136

User Information

Name: S P INTERNATIONAL ROAD Mobile: 9455140000

Email: spinternationalschoolmamri@gmail.com Pin Code: 262802

Full Address: Village- Dhirawa, Gram Panchayat- Dhirawa, Block- Kumbhigola, District- Kheri, State- Uttar Pradesh

Sample description

Source of Sample: S P INTERNATIONAL SCHOOL Village: Dhirawa

Gram Panchayat: Dhirawa Block: Kumbhigola

District: Kheri State: Uttar Pradesh

Address: Remarks:

Latitude: 27.885815 Longitude: 80.643297

Date & time of sample collection

22.05.2026 | 11:58:00 AM

Date & time of sample received in lab

22.05.2026 | 02:54:00 PM

Date & time of sample analysed

23.05.2026 | 02:56:00 PM

Date & time of report generation

23.05.2026 | 03:55:15 PM

Test results

S. No.	Parameters tested	Unit of measurement	Requirement (acceptable limit) as per BIS 10500	Permissible limit (in absence of alternate source) as per BIS 10500	Test result value	Method of Analysis	Remarks
1	Calcium (as Ca)*	mg/l	75	200	51.200	EDTA Titrimetric method	

	Parameters tested	Unit of measurement	Requirement (acceptable limit) as per BIS 10500	Permissible limit (in absence of alternate source) as per BIS 10500	Test result value	Method of Analysis	Remarks
2	Chloride (as Cl)*	mg/l	250	1000	13.999	Argentometric method	
3	Colour*	Hazen units	5	15	1.000	Visual comparison method	
4	Fluoride (as F)*	mg/l	1	1.5	0.253	Ion selective electrode method	
5	Iron (As Fe)*	mg/l	1	No Relaxation	0.125	Phenanthroline method or as per IS 15303:2002 Electrothermal atomic absorption/Spectrophotometer method	
6	Magnesium (As Mg)*	mg/l	30	100	14.200	Calculation by APHA	
7	Nitrate (as NO ₃)*	mg/l	45	No Relaxation	0.754	UV-Visible Spectrophotometer	
8	pH*	NA	6.5-8.5	No Relaxation	7.690	Electrometric method	
9	Sulphate (as SO ₄)*	mg/l	200	400	0.925	Turbidimetric method	
10	TDS*	mg/l	500	2000	215.200	Gravimetric method	
11	Total Alkalinity (as Calcium Carbonate)*	mg/l	200	600	176.000	Titration method	
12	Total Hardness (As CaCO ₃)*	mg/l	200	600	188.000	EDTA Titrimetric method	
13	Turbidity*	NTU	1	5	0.430	Nephelometric method	

Note:

- 1)*Indicates parameters that are NABL accredited.
- 2)This test results related to the sample tested above
- 3)The report shall not to be reproduced in full without approval of authority
- 4)This is the end of the report

Data prepared by

Chemist: (Deepak Mishra)

Authorised signatory
Ankur Dixit (Test Lab Incharge)

*****this is an electronically generated report and does not require a signature*****

State of notale tap water supply to every home

Page No. 1 of 1